



Punjab Fire Services (Ludhiana MC)



FIRE SAFETY CERTIFICATE ਫਾਇਰ ਸੇਫਟੀ ਪ੍ਰਮਾਣ ਪੱਤਰ

NOC No 1211-102555-Fire/79901

NOC Type: Renew

Dated **19-Dec-2024**

Certified that the **INDUS WORLD SCHOOL** at **RAJGARH ESTATE CANAL ROAD LUDHIANA** comprised of 0 basements and 3 (Upper floor) owned/occupied by **Davinder Bhasin** have complied with the fire prevention and fire safety requirements of National Building Code and verified by the officer concerned of fire service on **17-Dec-2024** in the presence of **Davinder Bhasin** (Name of the owner or his representative) and that the building / premises is fit for occupancy group **EDUCATIONAL BUILDING-B** subdivision **B-1** (As per NBC) for period of **one year** from issue date. Subject to the following conditions.

Issued on **19-Dec-2024** at **Ludhiana MC**

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ **INDUS WORLD SCHOOL** ਜੋ ਕਿ **RAJGARH ESTATE CANAL ROAD LUDHIANA** ਸਮੇਤ 0 ਬੇਸਮੈਂਟ ਅਤੇ 3 (ਉਪਰਲੀ ਮੰਜ਼ਿਲ) ਮਲਕੀਅਤ/ਕਾਬਜ਼ਦਾਰ **Davinder Bhasin** ਨੂੰ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਪ੍ਰਭਾਵੀ ਅਤੇ ਬਚਾਅ ਦੇ ਰਾਸ਼ਟਰੀ ਬਿਲਡਿੰਗ ਕੋਡ ਅਨੁਸਾਰ ਜਿਸ ਨੂੰ ਸਬੰਧਤ ਅੱਗ ਬੁਝਾਉ ਅਧਿਕਾਰੀ ਵੱਲੋਂ ਪ੍ਰਮਾਣਿਤ ਕੀਤਾ ਗਿਆ **17-Dec-2024** ਮੌਜੂਦਗੀ ਵਿੱਚ **Davinder Bhasin** (ਮਾਲਕ ਦਾ ਨਾਮ ਜਾਂ ਉਸ ਦਾ ਪ੍ਰਤੀਨਿਧੀ) ਅਤੇ ਇਮਾਰਤ / ਬਿਲਡਿੰਗ ਆਬਾਦੀ ਲਈ ਯੋਗ ਹੋ। Occupancy Group **EDUCATIONAL BUILDING-B** subdivision **B-1** (ਐਨ. ਬੀ. ਸੀ. ਦੇ ਅਨੁਸਾਰ) ਦੇ ਪ੍ਰਭਾਵੀ ਸਮੇਂ ਤੋਂ ਇੱਕ ਸਾਲ ਤੱਕ। ਜਿਸ ਲਈ ਨਿਮਨ ਅਨੁਸਾਰ ਹਦਾਇਤਾਂ ਹਨ।

ਜਾਰੀ ਕਰਨ ਦੀ ਮਿਤੀ **19-Dec-2024** ਕਿੱਥੇ **Ludhiana MC**.

1. Fire Safety arrangements shall be kept in working condition at all the times.
ਹਰ ਸਮੇਂ ਅੱਗ ਤੋਂ ਬਚਾਅ ਦੇ ਯੰਤਰਾਂ ਨੂੰ ਚਾਲੂ ਚੰਗੀ ਹਾਲਤ ਵਿੱਚ ਰੱਖਿਆ ਜਾਵੇ।
2. No, alteration/ addition/ change in use of occupancy is allowed.
ਕਿਸੇ ਵੀ ਤਰ੍ਹਾਂ ਦੇ ਬਦਲਾਅ/ ਵਾਧੇ/ ਕਾਬਜ਼ਕਾਰ ਵਿੱਚ ਬਦਲਾਵ ਦੀ ਮਨਾਹੀ ਹੈ।
3. Occupants/ owner should have trained staff to operate the operation of fire safety system provided there in.
ਉਪਲੱਬਧ ਅੱਗ ਬੁਝਾਉਣ ਦੇ ਯੰਤਰਾਂ ਦੀ ਵਰਤੋਂ ਤੋਂ ਰਕਿਣ ਵਾਲੇ ਲੋਕਾਂ / ਮਾਲਕਾਂ ਨੂੰ ਜਾਣੂੰ ਕਰਵਾਇਆ ਜਾਣਾ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ।

4. Fire Officer can check the arrangements of fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
ਫਾਇਰ ਬ੍ਰਿਗੇਡ ਅਧਿਕਾਰੀ ਕਿਸੇ ਵੀ ਵਕਤ ਇਨ੍ਹਾਂ ਸਾਰੇ ਪ੍ਰਬੰਧਾਂ ਨੂੰ ਚੈੱਕ ਕਰ ਸਕਦਾ ਹੈ, ਜੇ ਕਰ ਕੋਈ ਕਮੀ ਪਾਈ ਗਈ ਤਾਂ ਬਿਨਾਂ ਕਿਸੇ ਨੋਟਿਸ ਦੇ ਇਹ ਸਰਟੀਫਿਕੇਟ ਹੱਦ ਸਮੱਝਿਆ ਜਾਵੇਗਾ।

5. Occupants/ owner should apply for renewal of fire safety certificate one month prior to expiry of this certificate.
ਮਾਲਕ ਜਾਰੀ ਕੀਤੇ ਗਏ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੀ ਮਿਤੀ ਖਤਮ ਹੋਣ ਤੋਂ ਇੱਕ ਮਹੀਨਾ ਪਹਿਲਾਂ ਰੀਨੀਊ ਕਰਵਾਉਣ ਲਈ ਪਾਬੰਦ ਹੋਵੇਗਾ।

* Above Details cannot be used as ownership proof.

ਉਪਰੋਕਤ ਦਰਸਾਈ ਗਈ ਜਾਣਕਾਰੀ ਨੂੰ ਮਾਲਕਾਨਾ ਦੇ ਸਬੂਤ ਵਜੋਂ ਨਹੀਂ ਵਰਤਿਆ ਜਾਵੇਗਾ।

* This is digitally created cerificate, no signatue are needed

19	Detail of automatic fire detection system P.A. system provided in the building	NR
20	Detail of control panel	NR
21	Details of water storage capacity Underground / overhead with size of tank	10,000/ LTR
22	Detail of pumps with head and make	A) MAIN PUMP : 01 B) JOCKEY PUMP : 00 C) DIESEL PUMP : 00
23	Position of fire service inlet (2 way, 3 way, 4 way)	NR
24	No. of stair cases with size	2 (6.5 FT EACH)
25	No. of lift and ramps with details of communication system	2 RAMP (7 FT EACH)
26	Details of mean of escape	STAIRCASE, GATE, DOORS
27	Stand by source of power supply with all details of Gen set and location of switch details	GEN. SET- 40 KWH
28	Is building centrally air-conditioned. Give details	NO
29	Have all EXIT and directions of travel in each floor sign posted.	YES
30	Do the fire safety measures conform to the norms of NBC	
31	Whether earlier any NOC regarding fire safety, if yes 1. Name of the issuing authority, date, up to which date it was valid 2. whether after expiry of earlier NOC, Fresh NOC was issued, Give full details	RENEW 1211 79245-FIRE/59265
Recommendation of Inspection Officer:		
RECOMMENDED FOR APPROVAL		
ADFO	Signature Name of inspecting officer: RAJAN SINGH Designation: SFO Contact Number: 97818-15397	

PERFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE & SAFETY MEASURES
(High rise/multistory buildings, hospital, nursing homes, corporate offices, factories and Hazardous storages)

Sr. No.	Detail of Building/Premises	Date of inspect	17/12/24 Time 12:45
1	Name of the building /premises (Location/	Detail of the Building/Premises/fire safety measures	INDUS WORLD SCHOOL, RAJGARH ESTATE